


Ground Floor		
	pcs.	Power (W)
T5 2x28W/840	54	1492
18W/825 E27	0	0
35W/830 G12	4	140



No.	Floor	Room type	Area (m2)	Luminarie Type	Number of lamps	Power (W)	Total power (W)	Luminous flux (lm)	Total Luminous flux (lm)	Maintained illuminance (lx)	Standard illuminance (lx)	Light color	Min Total Luminous Flux (lm)
14	Ground Floor	Classroom	51,02	T5 2x28W/840	6	28	168	2600	15600	306	300	840	15306
15	Ground Floor	Classroom	73,08	T5 2x28W/840	10	28	280	2600	26000	356	300	840	21924
16	Ground Floor	Classroom	50,69	T5 2x28W/840	6	28	168	2600	15600	308	300	840	15207
17	Ground Floor	Office	23,70	T5 2x28W/840	6	28	168	2600	15600	658	500	840	11850
18	Ground Floor	Office	14,60	T5 2x28W/840	4	28	112	2600	10400	712	500	840	7300
19	Ground Floor	Classroom - Laboratory	64,36	T5 2x28W/840	8	28	224	2600	20800	323	300	840	19308
20	Ground Floor	Corridor	11,39	35W/830 G12	1	35	35	3600	3600	316	100	830	1139
21	Ground Floor	Classroom	56,19	T5 2x28W/840	8	28	224	2600	20800	370	300	840	16857
22	Ground Floor	Office	13,60	T5 2x28W/840	4	28	112	2600	10400	765	500	840	6800
23	Ground Floor	Library	16,34	T5 2x28W/840	2	18	36	1160	2320	142	100	825	1634
24	Ground Floor	Corridor	79,33	35W/830 G12	3	35	105	3600	10800	136	100	830	7933

DELTER

Support to Meet Requirements of the Energy Community Treaty for SEE Focusing on Energy Efficiency and Renewables

PROJECT:	Elementary School "Kardinala Stepinca" N
CADCODE:	NM-PLOTDRW-02
SCALE:	
DATE:	10.10.2011

