


Ground Floor		
	pcs.	Power (W)
T5 2x28W/840	108	3024
18W/825 E27	37	674
35W/830 G12	11	385



No.	Floor	Room type	Area (m2)	Luminarie Type	Number of lamps	Power (W)	Total power (W)	Luminous flux (lm)	Total Luminous flux (lm)	Maintained Illuminance (lx)	Standard Illuminance (lx)	Light color	Min Total Luminous Flux (lm)
1	Ground Floor	Classroom	12,00	T5 2x28W/840	2	28	56	2600	5200	433	300	840	3600
2	Ground Floor	Classroom	12,00	T5 2x28W/840	2	28	56	2600	5200	433	300	840	3600
3	Ground Floor	Classroom	12,00	T5 2x28W/840	2	28	56	2600	5200	433	300	840	3600
4	Ground Floor	Classroom	60,00	T5 2x28W/840	8	28	224	2600	20800	347	300	840	18000
5	Ground Floor	Classroom	16,00	T5 2x28W/840	2	28	56	2600	5200	325	300	840	4800
6	Ground Floor	Classroom	12,75	T5 2x28W/840	2	28	56	2600	5200	408	300	840	3825
7	Ground Floor	Storage	12,00	18W/825 E27	3	18	54	1160	3480	290	200	825	2400
8	Ground Floor	Storage	12,00	18W/825 E27	3	18	54	1160	3480	290	200	825	2400
9	Ground Floor	Dressroom	11,70	18W/825 E27	3	18	54	1160	3480	297	200	825	2340
10	Ground Floor	Toilet	8,40	18W/825 E27	2	18	36	1160	2320	276	200	825	1680
11	Ground Floor	Sport hall	231,70	T5 2x28W/840	28	28	784	2600	72800	314	300	840	69510
12	Ground Floor	Stairs	23,30	35W/830 G12	1	35	35	3600	3600	155	150	830	3480
13	Ground Floor	Stairs	36,00	35W/830 G12	2	35	70	3600	7200	200	150	830	5400
14	Ground Floor	Corridor	32,66	35W/830 G12	1	35	35	3600	3600	110	100	830	3266
15	Ground Floor	Entrance hall	138,75	T5 2x28W/840	12	28	336	2600	31200	225	200	840	27750
15a	Ground Floor	Corridor	17,28	35W/830 G12	1	35	35	3600	3600	208	100	830	1728
16	Ground Floor	Classroom	42,78	T5 2x28W/840	6	28	168	2600	15600	365	300	840	12834
17	Ground Floor	Classroom	18,60	T5 2x28W/840	4	28	112	2600	10400	559	300	840	5580
18	Ground Floor	Classroom	36,80	T5 2x28W/840	6	28	168	2600	15600	424	300	840	11040
19	Ground Floor	Toilet	7,00	18W/825 E27	2	18	36	1160	2320	331	200	825	1400
20	Ground Floor	Toilet	7,00	18W/825 E27	2	18	36	1160	2320	331	200	825	1400
21	Ground Floor	Storage	14,19	18W/825 E27	2	18	36	1160	2320	163	100	825	1419
22	Ground Floor	Storage	14,19	18W/825 E27	2	18	36	1160	2320	163	100	825	1419
23	Ground Floor	Storage	8,19	18W/825 E27	1	18	18	1160	1160	142	100	825	819
24	Ground Floor	Toilet	6,00	18W/825 E27	1	18	18	1160	1160	193	100	825	600
25	Ground Floor	Toilet	2,00	18W/825 E27	1	18	18	1160	1160	580	100	825	200
26	Ground Floor	Toilet	2,00	18W/825 E27	1	18	18	1160	1160	580	200	825	400
28	Ground Floor	Ports	10,00	T5 2x28W/840	2	28	56	2600	5200	520	500	840	5000
29	Ground Floor	Corridor	110,26	35W/830 G12	4	35	140	3600	14400	131	100	830	11026
30	Ground Floor	Stairs	22,80	35W/830 G12	1	35	35	3600	3600	158	150	830	3420
31	Ground Floor	Classroom	28,56	T5 2x28W/840	4	28	112	2600	10400	364	300	840	8568
32	Ground Floor	Corridor	4,29	18W/825 E27	1	26	26	1160	1160	270	100	825	429
33	Ground Floor	Classroom	47,40	T5 2x28W/840	6	28	168	2600	15600	329	300	840	14220
34	Ground Floor	Classroom	8,32	T5 2x28W/840	2	28	56	2600	5200	625	300	840	2496
35	Ground Floor	Classroom	61,44	T5 2x28W/840	8	28	224	2600	20800	339	300	840	18432
36	Ground Floor	Classroom	61,44	T5 2x28W/840	8	28	224	2600	20800	339	300	840	18432
37	Ground Floor	Classroom	10,00	T5 2x28W/840	2	28	56	2600	5200	520	300	840	3000
38	Ground Floor	Classroom	8,00	T5 2x28W/840	2	28	56	2600	5200	650	300	840	2400
39	Ground Floor	Toilet	8,00	18W/825 E27	2	18	36	1160	2320	290	200	825	1600
40	Ground Floor	Corridor	10,00	35W/830 G12	1	35	35	3600	3600	360	100	830	1000
41	Ground Floor	Storage	12,30	18W/825 E27	2	18	36	1160	2320	189	100	825	1230
42	Ground Floor	Storage	12,30	18W/825 E27	2	18	36	1160	2320	189	100	825	1230
43	Ground Floor	Storage	12,30	18W/825 E27	2	18	36	1160	2320	189	100	825	1230
44	Ground Floor	Toilet	2,00	18W/825 E27	1	18	18	1160	1160	580	200	825	400
45	Ground Floor	Toilet	2,00	18W/825 E27	1	18	18	1160	1160	580	200	825	400
46	Ground Floor	Toilet	2,00	18W/825 E27	1	18	18	1160	1160	580	200	825	400
47	Ground Floor	Toilet	2,00	18W/825 E27	1	18	18	1160	1160	580	200	825	400
48	Ground Floor	Toilet	2,00	18W/825 E27	1	18	18	1160	1160	580	200	825	400

DELTER

Support to Meet Requirements of the Energy Community Treaty for SEE Focusing on Energy Efficiency and Renewables

PROJECT: Elementary School "Sveti Sava" Zvornik

CADCODE: ZVR-PLOTDRW-01

SCALE:

DATE: 10.10.2011



A project implemented by EPTISA in Consortium with MVV and Kantor

